



## Izjava o svojstvima Declaration of Performance

CPR-20-13-201-HR-EN

1. Jedinstvena identifikacijska oznaka vrste proizvoda / Unique identification code of the product-type:  
**BE-PSE12-P**
2. Namjena/namjene / Intended use/es:  
**Sustavi za otkrivanje i dojavu požara – Oprema za napajanje energijom**  
**Power supply equipment for fire detection and fire alarm systems**
3. Proizvođač / Manufacturer  
**Schrack Seconet AG, Eibesbrunnergasse 18, 1120 Beč / Vienna**
5. Sustav/sustavi za ocjenu i provjeru stalnosti svojstava (AVCP) / System/s of assessment and verification of constancy of performance  
**1**
6. Usklađena norma / Harmonised standard(s):  
**EN 54-4:1997 + A1:2002 + A2:2006**

Prijavljeno tijelo/prijavljena tijela / Notified Body/ies:

**0786**  
**VdS Schadenverhütung GmbH**

7. Objavljena svojstva / Declared performance/s

Bitna obilježja	Essential characteristics	Svojstvima Performance	Harmonizacija tehničke specifikacije Harmonised technical specification	Odjeljak Clause
Učinak u slučaju požara	Performance under fire conditions	položeno pass	EN 54-4:1997 +A1:2002 +A2:2006	4 – 6
Pogonska pouzdanost	Operational reliability	položeno pass	EN 54-4:1997 +A1:2002 +A2:2006	4 – 8
Trajnost pogonske pouzdanosti otpornost na temperaturu	Durability of operational reliability, temperature resistance	položeno pass	EN 54-4:1997 +A1:2002 +A2:2006	9.5
Trajnost pogonske pouzdanosti otpornost na vibracije	Durability of operational reliability, vibration resistance	položeno pass	EN 54-4:1997 +A1:2002 +A2:2006	9.7 – 9.8, 9.15
Trajnost pogonske pouzdanosti električna stabilnost	Durability of operational reliability, electrical stability	položeno pass	EN 54-4:1997 +A1:2002 +A2:2006	9.9 – 9.13
Trajnost pogonske pouzdanosti otpornost na vlagu u zraku	Durability of operational reliability, humidity resistance	položeno pass	EN 54-4:1997 +A1:2002 +A2:2006	9.6, 9.14

SCHRACK SECONET AG • Eibesbrunnergasse 18 • A-1120 Wien  
UniCredit Bank Austria AG • Konto-Nr. 09493 191 200 • BLZ 12000 • IBAN AT96 1100 0094 9319 1200 • BIC BKAUATWW  
FN 123356g Handelsgericht Wien • ARA 9588 • DVR 0785083 • UID ATU 37395207

GESCHÄFTSSTELLEN: WIEN, NIEDERÖSTERREICH und BURGENLAND: Eibesbrunnergasse 18, A-1120 Wien, Tel.: +43-1-811 57-0\*, Fax: +43-1-811 57-222  
KUNDENDIENST WIEN: Tel.: +43-1-811 03-0\*, Fax: +43-1-811 57-500.

OBERÖSTERREICH: Kornstraße 16, A-4080 Leonding Hart, Tel.: +43-732-677 900-0\*, Fax: +43-732-677 900-20, SALZBURG: Vogelweidestraße 44a, A-5020 Salzburg, Tel.: +43-662-887 122-0\*, Fax: +43-662-887 122-73,  
TIROL: Dr.-Franz-Werner-Straße 36, A-6020 Innsbruck, Tel.: +43-512-365 366-0\*, Fax: +43-512-365 366-30, VORARLBERG: Sebastianstraße 13a, A-6850 Dornbirn, Tel.: +43-5572-511 99-0\*, Fax: +43-5572-511 99-30,  
STEIERMARK: Neuseiersberger Straße 157, A-8055 Graz, Tel.: +43-316-407 676-0\*, Fax: +43-316-407 676-35, KÄRNTEN: Feldkirchner Straße 138, A-9020 Klagenfurt, Tel.: +43-463-429 362-0\*, Fax: +43-463-429 362-25

Prije utvrđeno svojstvo proizvoda u skladu je s objavljenim svojstvima. Ova izjava o svojstvima izdaje se, u skladu s Uredbom (EU) br. 305/2011, pod isključivom odgovornošću prethodno utvrđenog proizvođača.  
The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Za proizvođača i u njegovo ime potpisao / Signed for and on behalf of the manufacturer by:

Schrack Seconet AG

Beč / Vienna

05.05.2017

ppa.



Thomas Kern  
Voditelj Odjela za upravljanje proizvodom  
i centra kompetencije /  
Head of Product Management  
and Competence Center

ppa.



Heinz Kohlenberger  
Voditelj razvojnog odjela /  
Head of Development



#### NAPOMENA

Neispravna uporaba ili instalacija uređaja može uzrokovati tjelesne ozljede i materijalne štete.  
Za točnu instalaciju i rukovanje pogledajte upute za instalaciju:  
<https://www.schrack-seconet.com/en/services/downloadcenter> → B-TD-BE-PSE-P  
Prije nego što počnete s instalacijom, pročitajte pažljivo sigurnosne napomene i pridržavajte ih se.



#### NOTE

Improper use or installation of the device can lead to injury or damages.  
For the exact procedure for proper installation and handling, please refer to the manufacturer documentation:  
<https://www.schrack-seconet.com/en/services/downloadcenter> → B-TD-BE-PSE-P  
Please read this document carefully and follow the safety instructions before you begin with the installation.