



Izjava o svojstvima Declaration of Performance

CPR-20-13-101-HR-EN

1. Jedinstvena identifikacijska oznaka vrste proizvoda / Unique identification code of the product-type:

BX-SBL501, BX-SBL502

2. Namjena/namjene / Intended use/es:

Sustavi za otkrivanje i dojavu požara – akustičan davač signala za sustave dojave požara

Fire alarm devices - sounder for fire detection and fire alarm systems

3. Proizvođač / Manufacturer:

Schrack Seconet AG, Eibesbrunnergasse 18, 1120 Beč / Vienna

5. Sustav/sustavi za ocjenu i provjeru stalnosti svojstava (AVCP) / System/s of assessment and verification of constancy of performance

1

6. Usklađena norma / Harmonised standard(s):

EN 54-3:2001 + A1:2002 + A2:2006

EN 54-17:2005 + AC:2007

Prijavljeno tijelo/prijavljena tijela / Notified Body/ies:

0786

VdS Schadenverhütung GmbH

7. Objavljena svojstva / Declared performance/s

Bitna obilježja	Essential characteristics	Svojstvima Performance	Harmonizacija tehničke specifikacije Harmonised technical specification	Odjeljak Clause
Učink u slučaju požara	Performance under fire conditions	položeno pass	EN 54-3:2001 + A1:2002 +A2:2006	4.2 – 4.3, 4.4.1 – 4.4.2, 5.2 – 5.3, 5.18 – 5.20
Pogonska pouzdanost	Operational reliability	položeno pass	EN 54-3:2001 + A1:2002 +A2:2006	4.4 – 4.6, 5.4
Trajnost pogonske pouzdanosti otpornost na temperature	Durability of operational reliability, temperature resistance	položeno pass	EN 54-3:2001 + A1:2002 +A2:2006	5.5 – 5.9
Trajnost pogonske pouzdanosti otpornost na vlagu u zraku	Durability of operational reliability, humidity resistance	položeno pass	EN 54-3:2001 + A1:2002 +A2:2006	5.8 – 5.10
Trajnost pogonske pouzdanosti otpornost na koroziju	Durability of operational reliability, corrosion resistance	položeno pass	EN 54-3:2001 + A1:2002 +A2:2006	5.11
Trajnost pogonske pouzdanosti otpornost na udarce i vibracije	Durability of operational reliability, shock and vibration resistance	položeno pass	EN 54-3:2001 + A1:2002 +A2:2006	5.12 – 5.15

SCHRACK SECONET AG • Eibesbrunnergasse 18 • A-1120 Wien
UniCredit Bank Austria AG • Konto-Nr. 09493 191 200 • BLZ 12000 • IBAN AT96 1100 0094 9319 1200 • BIC BKAUATWW
FN 123356g Handelsgericht Wien • ARA 9588 • DVR 0785083 • UID ATU 37395207

GESCHÄFTSSTELLEN: WIEN, NIEDERÖSTERREICH und BURGENLAND, Eibesbrunnergasse 18, A-1120 Wien, Tel.: +43-1-811 57 0*, Fax: +43-1-811 57-222

KUNDENDIENST WIEN: Tel.: +43-1-811 03-0*, Fax: +43-1-811 57-500.

OBERÖSTERREICH: Kornstraße 16, A-4060 Leonding-Hart, Tel.: +43-732-877 900-0*, Fax: +43-732-877 900-20, SALZBURG: Vogelweiderstraße 44a, A-5020 Salzburg, Tel.: +43-662-887 122-0*, Fax: +43-662-887 122-73,
TIROL: Dr.-Franz-Werner-Straße 36, A-6020 Innsbruck, Tel.: +43-512-365 386-0*, Fax: +43-512-365 386-30, VORARLBERG: Sebastiansstraße 13a, A-6850 Dornbirn, Tel.: +43-5572-511 99-0*, Fax: +43-5572-511 99-30,
STEIERMARK: Neuseiersberger Straße 157, A-8055 Graz, Tel.: +43-316-407 676-0*, Fax: +43-316-407 676-35, KÄRNTEN: Feldkirchner Straße 138, A-9020 Klagenfurt, Tel.: +43-483-429 362-0*, Fax: +43-483-429 362-25

Ein Unternehmen der Securitas Gruppe Schweiz

Trajnost pogonske pouzdanosti električna stabilnost	Durability of operational reliability, electrical stability	položeno pass	EN 54-3:2001 + A1:2002 +A2:2006	5.16
Trajnost pogonske pouzdanosti otpornost na prodore	Durability of operational reliability, resistance to ingress	položeno pass	EN 54-3:2001 + A1:2002 +A2:2006	5.17
Učinak u slučaju požara	Performance under fire conditions	položeno pass	EN 54-17:2005 +AC:2007	5.2
Pogonska pouzdanost	Operational reliability	položeno pass	EN 54-17:2005 +AC:2007	4
Trajnost pogonske pouzdanosti otpornost na temperature	Durability of operational reliability, temperature resistance	položeno pass	EN 54-17:2005 +AC:2007	5.4 – 5.5
Trajnost pogonske pouzdanosti otpornost na vibracije	Durability of operational reliability, vibration resistance	položeno pass	EN 54-17:2005 +AC:2007	5.9 – 5.12
Trajnost pogonske pouzdanosti otpornost na vlagu u zraku	Durability of operational reliability, humidity resistance	položeno pass	EN 54-17:2005 +AC:2007	5.6 – 5.7
Trajnost pogonske pouzdanosti otpornost na koroziju	Durability of operational reliability, corrosion resistance	položeno pass	EN 54-17:2005 +AC:2007	5.8
Trajnost pogonske pouzdanosti električna stabilnost	Durability of operational reliability, electrical stability	položeno pass	EN 54-17:2005 +AC:2007	5.3, 5.13

Prije utvrđeno svojstvo proizvoda u skladu je s objavljenim svojstvima. Ova izjava o svojstvima izdaje se, u skladu s Uredbom (EU) br. 305/2011, pod isključivom odgovornošću prethodno utvrđenog proizvođača./

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Za proizvođača i u njegovo ime potpisao / Signed for and on behalf of the manufacturer by:

Schrack Seconet AG

Beč / Vienna

05.05.2017

ppa.



Thomas Kern
Voditelj Odjela za upravljanje proizvodom
i centra kompetencije /
Head of Product Management
and Competence Center

ppa.



Heinz Kohlerberger
Voditelj razvojnog odjela /
Head of Development



NAPOMENA

Neispravna uporaba ili instalacija uređaja može uzrokovati tjelesne ozljede i materijalne štete.

Za točnu instalaciju i rukovanje pogledajte upute za instalaciju:

<https://www.schrack-seconet.com/de/services/downloadcenter> → B-HB-070

Prije nego što počnete s instalacijom, pročitajte pažljivo sigurnosne napomene i pridržavajte ih se.



NOTE

Improper use or installation of the device can lead to injury or damages.

For the exact procedure for proper installation and handling, please refer to the manufacturer documentation:

<https://www.schrack-seconet.com/en/services/downloadcenter> → B-HB-070

Please read this document carefully and follow the safety instructions before you begin with the installation.