



Izjava o svojstvima Declaration of Performance

CPR-20-13-002-HR-EN

1. Jedinstvena identifikacijska oznaka vrste proizvoda / Unique identification code of the product-type:

Integral IP CXF, Integral IP CXE

2. Namjena/namjene / Intended use/es:

Sustavi dojave požara – centrale dojave požara

Fire detection and fire alarm systems - Control and indicating equipment

3. Proizvođač / Manufacturer

Schrack Seconet AG, Eibesbrunnnergasse 18, 1120 Beč / Vienna

5. Sustav/sustavi za ocjenu i provjeru stalnosti svojstava (AVCP) / System/s of assessment and verification of constancy of performance

1

6. Usklađena norma / Harmonised standard(s):

EN 54-2:1997 + A1:2006

EN 54-4:1997 + A1:2002 + A2:2006

EN 12094-1:2003 + A1:2006

Prijavljeno tijelo/prijavljena tijela / Notified Body/ies:

0786

VdS Schadenverhütung GmbH

7. Objavljena svojstva / Declared performance/s

Bitna obilježja	Essential characteristics	Svojstvima Performance	Harmonizacija tehničke specifikacije Harmonised technical specification	Odjeljak Clause
Učinak u slučaju požara	Performance under fire conditions	položeno pass	EN 54-2:1997 +A1:2006	4 – 5, 7
Odgoda aktivacije (vrijeme aktivacije pri alarmu)	Response delay (response time to fire)	položeno pass	EN 54-2:1997 +A1:2006	7.1, 7.7, 7.11 – 7.12
Pogonska pouzdanost	Operational reliability	položeno pass	EN 54-2:1997 +A1:2006	4 - 14
Trajnost pogonske pouzdanosti otpornost na temperaturu	Durability of operational reliability, temperature resistance	položeno pass	EN 54-2:1997 +A1:2006	15.4
Trajnost pogonske pouzdanosti otpornost na vibracije	Durability of operational reliability, vibration resistance	položeno pass	EN 54-2:1997 +A1:2006	15.6 – 15.7, 15.15
Trajnost pogonske pouzdanosti električna stabilnost	Durability of operational reliability, electrical stability	položeno pass	EN 54-2:1997 +A1:2006	15.8 - 15.13
Trajnost pogonske pouzdanosti otpornost na vlagu u zraku	Durability of operational reliability, humidity resistance	položeno pass	EN 54-2:1997 +A1:2006	15.5, 15.14

SCHRACK SECONET AG • Eibesbrunnnergasse 18 • A-1120 Wien
UniCredit Bank Austria AG • Konto-Nr. 09493 191 200 • BLZ 12000 • IBAN AT96 1100 0094 9319 1200 • BIC BKAUATWW
FN 123356g Handelsgericht Wien • ARA 9588 • DVR 0785083 • UID ATU 37395207

GESCHÄFTSSTELLEN, WIEN, NIEDERÖSTERREICH und BURGENLAND: Eibesbrunnnergasse 18, A-1120 Wien, Tel.: +43-1-811 57 0*, Fax: +43-1-811 57-222
KUNDENDIENST WIEN: Tel.: +43-1-811 03 0*, Fax: +43-1-811 57-500

OBERÖSTERREICH: Kornstraße 16, A-4060 Leonding-Hart, Tel.: +43-732-677 900-0*, Fax: +43-732-677 900-20, SALZBURG: Vogelweiderstraße 44a, A-5020 Salzburg, Tel.: +43-662-887 122-0*, Fax: +43-662-887 122-73,
TIROL: Dr. Franz Werner-Straße 36, A-6020 Innsbruck, Tel.: +43-512-365 366 0*, Fax: +43-512-365 366 30, VORARLBERG: Sebastianstraße 13a, A-6850 Dornbirn, Tel.: +43-5572-511 99 0*, Fax: +43-5572-511 99-30,
STEIERMARK: Neuseiersberger Straße 157, A-8055 Graz, Tel.: +43-316-407 676 0*, Fax: +43-316-407 676-35, KÄRNTEN: Feldkirchner Straße 138, A-9020 Klagenfurt, Tel.: +43-483-429 362 0*, Fax: +43-483-429 362-25

Učinkak u slučaju požara	Performance under fire conditions	položeno pass	EN 54-4:1997 +A1:2002 +A2:2006	4 – 6
Pogonska pouzdanost	Operational reliability	položeno pass	EN 54-4:1997 +A1:2002 +A2:2006	4 – 8
Trajnost pogonske pouzdanosti otpornost na temperature	Durability of operational reliability, temperature resistance	položeno pass	EN 54-4:1997 +A1:2002 +A2:2006	9.5
Trajnost pogonske pouzdanosti otpornost na vibracije	Durability of operational reliability, vibration resistance	položeno pass	EN 54-4:1997 +A1:2002 +A2:2006	9.7 – 9.8, 9.15
Trajnost pogonske pouzdanosti električna stabilnost	Durability of operational reliability, electrical stability	položeno pass	EN 54-4:1997 +A1:2002 +A2:2006	9.9 – 9.13
Trajnost pogonske pouzdanosti otpornost na vlagu u zraku	Durability of operational reliability, humidity resistance	položeno pass	EN 54-4:1997 +A1:2002 +A2:2006	9.6, 9.14
Odgoda aktivacije (vrijeme aktivacije)	Response delay (response time)	položeno pass	EN 12094-1:2003 + A1:2006	4.8
Pogonska pouzdanost	Operational reliability	položeno pass	EN 12094-1:2003 + A1:2006	4 – 6
Učinkak u slučaju požara	Performance under fire conditions	položeno pass	EN 12094-1:2003 + A1:2006	4.3 – 4.6
Trajnost	Durability	položeno pass	EN 12094-1:2003 + A1:2006	9

Prije utvrđeno svojstvo proizvoda u skladu je s objavljenim svojstvima. Ova izjava o svojstvima izdaje se, u skladu s Uredbom (EU) br. 305/2011, pod isključivom odgovornošću prethodno utvrđenog proizvođača.
The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Za proizvođača i u njegovo ime potpisao / Signed for and on behalf of the manufacturer by:

Schrack Seconet AG

Beč / Vienna

05.05.2017

ppa.


Thomas Kern
Voditelj Odjela za upravljanje proizvodom i centra kompetencije /
Head of Product Management and Competence Center

ppa.


Heinz Kohlenberger
Voditelj razvojnog odjela /
Head of Development



NAPOMENA

Neispravna uporaba ili instalacija uređaja može uzrokovati tjelesne ozljede i materijalne štete.
Za točnu instalaciju i rukovanje pogledajte upute za instalaciju:
<https://www.schrack-seconet.com/en/services/downloadcenter> → B-HB-068
Prije nego što počnete s instalacijom, pročitajte pažljivo sigurnosne napomene i pridržavajte ih se.



NOTE

Improper use or installation of the device can lead to injury or damages.
For the exact procedure for proper installation and handling, please refer to the manufacturer documentation:
<https://www.schrack-seconet.com/en/services/downloadcenter> → B-HB-068
Please read this document carefully and follow the safety instructions before you begin with the installation.